2017 CERTIFICATION

Consumer Confidence Report (CCR)

2018 MAY 11 AM 9: 41

BarronTown Utility Association Inc. Public Water System Name

0180001

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.					
Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)					
Advertisement in local paper (Attach copy of advertisement)					
On water bills (Attach copy of bill)					
☐ Email message (Email the message to the address below)					
Other Website, Posted @ Drive Thru & Entry @ Water OFC/Oogy ATTached					
Date(s) customers were informed: 04/26/2018 05/02-2018 04/30/2018 CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery					
CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used					
Date Mailed/Distributed: / /					
CCR was distributed by Email (Email MSDH a copy) Date Emailed: / /2018					
☐ As a URL(Provide Direct URL)					
☐ As an attachment					
☐ As text within the body of the email message					
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)					
Name of Newspaper: Hatt ies burg Publishing, INC / The Petal News					
Date Published: <u>04 /26 / 20 18</u>					
CCR was posted in public places. (Attach list of locations) Date Posted: / / 2018					
CCR was posted on a publicly accessible internet site at the following address:					
CERTIFICATION hote: 11barrantown water org/assets/file/ccl. pdf (Provide Direct URL)					
I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply					
5-8-2018					
Name/Title (President, Mayor, Owner, etc.) Date					
Submission options (Select one method ONLY)					
Mail: (IIC Bartel Compile)					

Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700

Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2018!

2017 Annual Drinking Water Quality Report Barrontown Utility Association PWS#: 0180001

PWS#: 0180001 April 2018



We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water

If you have any questions about this report or concerning your water utility, please contact Elaine Tolbert, General Manager, at 601.544.3502. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting held the second Monday of November at 7:00 PM at the Barrontown Community Center, 610 Herrington Road, Petal, MS.

Our water source is from wells drawing from the Lower and Middle Catahoula Formation Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Barrontown Utility Association have received lower susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

(7)				TEST R	ESULI	r s		
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioacti 5. Gross Alpha	ve Cont	aminan	1 ts	No Range	pCi/L	01	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2016	6 <.7	No Range	pCi/L	Ö	5	Erosion of natural deposits
Inorganic	Contai	ninants	.0351	.00330351	ppm	2	2	Discharge of drilling wastes; discharg from metal refineries; erosion of nature deposits

14. Copper	N	2014/16*	,1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.244	.15244	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Volatile O 74. Toluene	N	2017	.001	No Range	ppm	1	1	Discharge from petroleum factories
**************************************				I No Kange	[ppm	1	11	Discharge from petroleum factories
Disinfection	и Бу	-Product	S					
81. HAA5	N	2014*	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes	N	2014*	5.96	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	1.6	1.18 - 2.18	ppm	0	MDRL = 4	Water additive used to control microbes

^{*} Most recent sample. No sample required for 2017.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Barrontown Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please note: This report will not be mailed out to customers individually, however a copy may be requested from our office located at 101 Dogwood Lane, Petal, MS or visit our website at barrontownwater.org

2018 MAY 11 AM 9: 41

Barrontown Utility Association, Inc.

101 Dogwood Lane ~ Petal, MS 39465 ~ Phone 601-544-3502 ~ Fax 601-544-3677

May 8, 2018

Mississippi State Department of Health Bureau of Public Water Supply P. O. Box 1700 Jackson, Mississippi 39215-1700

RE: 2017 CCR

Dear Sir:

Please find the enclosed 2017 Consumer Confidence Report and Certification Form for Barrontown Utility Association, Inc. dated May 8, 2018 and published in the local newspaper on April 26, 2018. Also attached is our proof of publication that is notarized and dated April 26, 2018.

Barrontown Utility Association, Inc. has complied with all the regulations established for systems serving fewer than 10,000 persons in connection with this report.

If you have any questions, please call me @ 601-544-3502.

Cordially,

Elaine Tolbert, General Manager Barrontown Utility Association

Elaine Jelber

Attachments: 5

Hattiesburg Publishing, Inc.

103 N. 40th Ave. • Hattiesburg, MS 39401 (601) 268-2331 tel • (601) 268-2965 fax

2018 MAY 11 AM 9: 41

RECEIVED

Proof of Publication

THE STATE OF MISSISSIPPI, LAMAR COUNTY, FORREST COUNTY Personally appeared before me, the undersigned, Brittany Purvis, Legal Advertising Clerk, for The LAMAR TIMES, The PETAL NEWS, and The HATTIESBURG POST weekly newspapers published in Lamar County and Forrest County, Mississippi respectively, who, being duly sworn, says that the notice, a true copy of which is hereto annexed, appeared in the issues of said newspapers as follows:

. J(: o # lata	f Words: <u>4x16</u> p	ublished 1 times
9		Published: <u>04. 26.18</u>	,
		Published:	
D	ate 3rd	Published:	Amt:
D	ate 4th	Published:	Amit*
* - D	ote 5th	Published:	Ami:
		Subtotal Printer's Fee:	448.a
		Proof of Publication Fee:	117
Sv do ar	vorn to ry of	and subscribed before me in my P	OSERICE This 26th
	FOF	R OFFICE USE ONLY	mission Fagires 2014, 2019
		Emp: brongit	7 COVII.
		App: 04.24.18	7
		File Title	
		Invoice # 8164	
		Inv. Crt/Mld: 04-20	6.18
		Pyrnt Rec.d:	
		POP sent: 04.26	18

2017 Annual Drinking Water Quality Report
Barrontown Utility Association
PWS#: 0180001
April 2018

If you have any questions about this report or concerning your water utility, please contact Etaine Tolbert, General Manager, at 601.544.3502. We want our valued customers to be Informed about their water utility. If you want to learn more, please attend the annual meeting held the second Monday of November at 7:00 PM at the Barrondown Community Center, 610 Harrington Road, Petal, MS. efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your year's Annual Quality Water Report. This report is designed to inform you about the qua int goal is to provide you with a safe and dependable supply of ditinking water. We w

containing detailed information on how the susceptibility determinations were made has been furnished to our public wa Our weter source is from wells drawing from the Lower and Middle Catahou'a Formation Aquifors. The source water

contaminants does not necessarily indicate that the water poses a health risk. expected to contain at may be reasonably

Action Level - the concentration of a contaminant which, if exceeded, biggers treatment or other requirements which a waser system must follow.

ACCOUNT NO.		SERVICE FROM	SERVICE TO
01	0006011 CE ADDRESS	04/01	04/30
10	32 MORR	ISTON ROA	D
cu	RRENT	PREVIOUS	USED
	166	166	
Name of	CHARG	GE FOR SERVICES	15 AU 1. 24 - 34 AU

12.00

13.20

14.40

1.20

WTR

PAST DUE

NET DUE >>> SAVE THIS >>

GROSS DUE >>

RETURN THIS STUB WITH PAYMENT TO: BARRONTOWN WATER ASSOCIATION 101 DOGWOOD LANE PETAL, MS 39465

159 PUMPING STATION RD

PETAL, MS 39465

39465

PRESORTED FIRST CLASS MAIL U.S. POSTAGE PAID PERMIT NO. 57 PETAL, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE 05/15/2018	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	SAVE THIS	GROSS AMOUNT
13.20	1_20	2 40
assets/file	rrontownwater. /ccr.pdf RN SERVICE REQUES	* * •
010006011		ED - WATER
AARON LEE H	INTON	6 5

BARRONTOWN WATER

2017 Annual Drinking Water Quality Report (CCR)

COPIES AVAILABLE IN OFFICE 101 Dogwood Lane Petal, MS 39465

> OR VISIT OUR WEB @ Barrontownwater.org

Posted - 4-26-18